


MIN. PIPE DIA.	2"	4"	6"	8"	10"	12"	15"	18"	
DIMENSION	A	4"	4"	4"	6"	6"	8"	10"	12"

NOTES:

1. FORCemain shall be either Ductile Iron Pipe (DIP) or Polyvinyl Chloride (PVC)
2. PVC shall be encased with bedding sand.
3. PVC FORCemain shall have a No. 10 gauge tracer wire attached to pipe. Tracer wire shall be brought to surface in handholes at every direction change beginning at the start of the pipe. Tracer wire shall be brought into manhole at the end of the pipe.



TYPICAL FORCemain TRENCH

SCALE: N.T.S.

FEBRUARY 2023

SA-019